

ADDENDUM NUMBER 1

PROJECT: City of Las Vegas
Dee Bibb Lift Station Improvements
Project Funding No. CWSRF 071
Stantec Project # 227300278

OWNER: City of Las Vegas

ENGINEER: Stantec CS

DATE: October 21, 2020

BID OPENING DATE: October 28, 2020 **TIME:** 2:30 p.m.

THE FOLLOWING CHANGES SHALL BE MADE IN THE BID DOCUMENTS.

<i>BID DOCUMENT</i>	<i>SECTION</i>	<i>DESCRIPTION</i>
Clarification	N/A	American Iron and Steel compliant materials are required for this project. All submittals for construction material shall be accompanied by AIS certification in order to be approved.
Clarification	N/A	Transition from stainless steel piping to ductile iron pipe shall be just outside the concrete basin. All new piping, hardware, and manifold inside the concrete basin shall be stainless steel.
Clarification	N/A	Dissimilar metal coupling installed between the stainless steel piping and the ductile iron piping shall be acceptable for this project. Dissimilar metal coupling shall be installed just outside the concrete basin. Dissimilar metal coupling shall be considered as part of bid item #2
Clarification	N/A	Ductile iron piping inside new fiberglass valve vault shall be considered as part of bid item #2.
Clarification	N/A	Flange insulation gaskets shall be acceptable for this project.



Ramses S. Ortega, P.E.
Stantec CS