

**ADDENDUM NO. 2
CITY OF LAS VEGAS
JULY 16, 2021**

TO: All Planholders

**RE: Hanna Park Effluent, June 2021
Drinking Water State Revolving Fund No.: DWSRF-5362**

The following Addendum shall be incorporated into the Contract Documents for the above-referenced project.

A. PROJECT MANUAL

1. BID FORM:
 - a. Revised Page BID-3 is included in this Addendum No.2 and is to be submitted in the Bid Package.

B. RESPONSES TO CONTRACTOR QUESTIONS (Responses are in **Bold/Italics.)**

1. Bid Item 1. Is for material only for 6" Pvc.

Bid Item 1 should not include trenching and backfilling. Trenching, backfilling and all associated materials and work is to be part of bid items 2 and 3.


2. Bid Item 2. Is for material only for 10" Pvc.

Bid Item 5 should not include trenching and backfilling. Trenching, backfilling and all associated materials and work is to be part of bid items 6 and 7.

3. Addendum #1 Question 19 Sheet W-104 approximately station 33 +00 shows crossing Mountain View Drive by connecting to an existing Line with 90 degree elbows. Is this connection point an line in use or a stub from a previous project.

The existing line is not in use, and was constructed as part of a previous project.

MOLZEN CORBIN



Jonah S. Ruybalid, P.E. Date 07-16-2021

D. Bidder has not engaged in corrupt, fraudulent, collusive, or coercive practices in competing for the Contract. For the purposes of this Paragraph 4.01.D:

1. "corrupt practice" means the offering, giving, receiving, or soliciting of any thing of value likely to influence the action of a public official in the bidding process;
2. "fraudulent practice" means an intentional misrepresentation of facts made (a) to influence the bidding process to the detriment of Owner, (b) to establish bid prices at artificial non-competitive levels, or (c) to deprive Owner of the benefits of free and open competition;
3. "collusive practice" means a scheme or arrangement between two or more Bidders, with or without the knowledge of Owner, a purpose of which is to establish bid prices at artificial, non-competitive levels; and
4. "coercive practice" means harming or threatening to harm, directly or indirectly, persons or their property to influence their participation in the bidding process or affect the execution of the Contract.

ARTICLE 5 – BASIS OF BID

5.01 Bidder shall complete the Work in accordance with the Contract Documents for the following price(s):

Item No.	Description	Unit	Est. Qty.	Bid Unit Price	Bid Price
1	6" PVC Effluent Pipe.	LF	4,400	\$	\$
2	Trenching and Backfilling, All Associated Work.	LF	3,900	\$	\$
3	Trenching and Backfilling with Rock Excavation, All Associated Work.	LF	500	\$	\$
4	6" Gate Valve with Valve Box.	EA	5	\$	\$
5	10" PVC Effluent Pipe.	LF	2,060	\$	\$
6	Trenching and Backfilling, All Associated Work.	LF	1,860	\$	\$
7	Trenching and Backfilling with Rock Excavation, All Associated Work.	LF	200	\$	\$
8	10" Gate Valve with Valve Box	EA	3	\$	\$
9	2" Air Vac Station Including Vault and All Associated Work.	EA	1	\$	\$
10	2" Schedule 80 Pipe Including Trenching, Backfilling and Cap.	LF	40	\$	\$
11	Directional Drill, 2" HDPE DR-9 Pipe.	LF	60	\$	\$
12	6" x 2" Tee and 2" Plug Valve with Valve Box.	EA	3	\$	\$
13	Fire Hydrant Painted Purple, Including Tee, Valve, and All Associated Work.	EA	1	\$	\$